

# **Model 740A Probe**

## **GENERAL DESCRIPTION**

The Model 740A is a general purpose rigid probe for use with capacitance instruments. It is used for level measuring applications involving liquids or dry materials. Available either bare (non-insulated) or Teflon insulated for use in conductive solutions. The Teflon electrode insulation has a Teflon wall thickness of 1/16" over a 7/32" 316 stainless steel sensing rod. The Teflon insulated probe is recommended for use on low viscosity liquids and low to medium density granular materials. (For abrasive or agitated products, see Model 728B Heavy Duty probes.)

The Model 740A Probe has been designed to ensure long, trouble-free life. Extra tight fitting Teflon insulation has been incorporated into the design of the Model 740A Probe series. This insulation is continuous through the total length of the probe including the gland with an internal stainless steel sheath over the Teflon inside the gland. If a seal should break down and allow leakage into the gland, this internal construction is such that the measurement will not be affected and reliable readings will continue.

The Model 740A Probe, except as noted, conforms to the requirements of the National Association Of Corrosion Engineers (NACE) specification MR0175-88 (Material requirements For Resistance To Sulfide Stress Cracking For Oilfield Equipment).

## APPLICATION DATA

When a probe is used with on-off (point level) instruments, it may be installed in the vessel either horizontally or vertically. For extremely small differential (deadband), the probe should be mounted in a horizontal position at the desired level point.

If the probe is to be used on a continuous level measurement application, the probe must be mounted in the vessel in a vertical position.

For low dielectric liquid applications, the Model 740A probe offers a concentric shield option over the sensing electrode.

Various gland materials and/or optional flanges are readily available to meet particular requirements.



- Non-shortable Gland Assembly
- Extra tight Fitting Teflon Insulation
- Many Options Available to Tailor Probe to Customers' Needs
- Available in Lengths to 20 Feet
- No Moving Parts
- Conformance to NACE MR0175-88 (Certain Models)

# **SPECIFICATIONS**

### Temperature/Pressure Ratings

Non-Insulated Probes	30" Hg to 2000 psi
	Up to 100°F.
	Derated to 0 psi @ 350°F.
Insulated Probes	30" Hg to 2000 psi
	Up to 100°F.
	Derated to 0 psi @ 350°F.
Gland Capacitance	
Probe Gain (insulated probe in	
conductive liquid)	60 pf/ft.
Sheath Capacitance	60 pf/ft.


# **ENGINEERING DATA**


Probe Rod Material (standard)
Probe Length (maximum) 20 feet
Gland Connection Size
Probe Diameter, Non-Insulated
Gland Materials: Standard
Sheath Material
Concentric Shield Material 316 stainless steel


# **DIMENSIONAL DATA**


#### MM INCH -

-










# **BEND DIMENSIONS**

Probe Style	Min	Minimum Lengths	
	L1	L2	L3
Basic Probe	2.00"	2.00"	-
With Straight Sheath *	3.50"	2.00"	-
With Bent Sheath	3.50"	4.50"	3.50"
With Welded Flange	3.50"	2.00"	-
With Welded Flange and	3.50"	2.00"	-
Straight Sheath *			
With Welded Flange and	4.75"	4.50"	3.50"
Bent Sheath			

\* Straight sheath must be at least 3.12" shorter than L1.

# **ORDERING INFORMATION**

Specify complete model number according to the tables below.



#### **KEY MODEL NUMBER**

HET MODEL NUMBER		
Model No.	Description	
740A	General Purpose capacitance or	
	conductivity probe. The probe utilizes	
	the patented, non-shorting gland	
	assembly.	

#### Table 1 - GLAND AND ROD MATERIAL

Desig.	Description
А	316 St. St. gland and 7/32" bare rod
В	316 St. St. gland with 3/8" O.D. Teflon over
	7/32" rod
С	Monel gland with 3/8" O.D. Teflon over
	7/32" St. St. rod
D	Hastelloy C gland with 3/8" O.D. Teflon
	over 7/32" St. St. rod

#### **Table 2 - PROBE ACTIVE LENGTH**

Desig.	Description
XXX	Specify active length in inches.
	Maximum length is 240". For insulated
	probes the insertion length is 1" longer
	than the active length due to the Teflon
	Tip.

#### **Table 3 - FLANGE OPTION**

Desig.	Description
Ν	None
А	Flange Screwed onto probe gland.
	Specify size and material.
B**	Flange welded to probe gland.
	Specify size and material.

\*\* Does not conform to NACE MR0175.

#### **Table 4 - ADDITIONAL OPTIONS**

Desig.	Description
0	None
1	Bent Probe. Specify Bending Dimensions.
	See Bending Dimension table and drawings.
2*	Sheath. Specify Sheath Length.
3*	Combination of 1 & 2 above.
4	Ground Wire Probe. Specify Material.
5*	Concentric shield.

### \* Does not conform to NACE MR0175.

Not available when specifying Monel or Hastelloy C gland (Table 1 Designations C and D).

#### Standard Flange Sizes

9
1" Class 150 Raised Face
1-1/2" Class 150 Raised Face
2" Class 150 Raised Face
3" Class 150 Raised Face
4" Class 150 Raised Face
1" Class 300 Raised Face
1-1/2" Class 300 Raised Face
2" Class 300 Raised Face
3" Class 300 Raised Face
4" Class 300 Raised Face

#### **Standard Flange Materials**

* Carbon Steel
* * 316 Stainless Steel

316L Stainless Steel

\* Does not conform to NACE MR0175.

\*\* Does not conform to NACE MR0175.

|--|

* 316 Stainless Steel
316L Stainless Steel
(not for dry products)
* Monel
* Hastelloy B
* Hastelloy C
* Tantalum
* Doos not conform to NACE MD0175

\* Does not conform to NACE MR0175.

#### NOTES:

1. The insertion length for insulated probes is 1" longer than the active length due to the Teflon Tip which is required for sealing the probe. For bare probes the insertion length is the same as the active length.

2. For simple bent probes, specify dimensions  $L_1$ ,  $L_2$ , the included angle and, if the sheath is bent,  $L_3$  as shown in the drawings. For more complicated bending submit a sketch with the order.

3. Probes may be supplied with flanges of different sizes, styles and materials than listed above by special order.



Schneider Electric Systems USA, Inc. 1602 Mustang Drive Maryville, Tennessee 37801 Phone: (865) 981-3100 Fax: (865) 981-3168 http://www.robertshawindustrial.com

Q-4072 (1/19) Printed in U.S.A.